

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50461253

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>	<i>(day/mo/yr)</i>
L.M.	01-Wuchale-50350053	001 16.03.2020	

Genehmigungsinhaber *License Holder*
Suntree Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang 325604
P. R. China

Fertigungsstätte *Manufacturing Plant*
Suntree Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang 325604
P. R. China

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1419079232

Geprüft nach *Tested acc. to*

EN 60947-3:2009+A1+A2

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

Lizenzentgelte - Einheit *License Fee - Unit*

Fuse Holder (Fuse-disconnector)

Type Designation	: CH-30, SRD-30	6
Trade mark	: Suntree (logo)	
Utilization Category	: DC-PV0	
Number of Pole	: 1 pole	
Rated Operational Voltage (Ue)	: DC 1100V	
Rated Operational Current (Ie)	: 1-30A	
Rated Insulation Voltage (Ui)	: 1200V	
Rated Impulse Withstand Voltage (Uimp)	: 6kV	
Conventional Free Air Thermal Current (Ith)	: 30A	
Rated Conditional Short-circuit Current	: 30kA	
Pollution Degree	: 3	



6

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Zhao Xinhua

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Suntree Electric Group Co., Ltd.
Maggie Liu
-
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang 325604
P. R. China

Date : 16.03.2020
Our ref. : Wuchale 01
Your ref.: L.M.

Ref : R TÜV-Mark Approval

Type of Equipment : Fuse-disconnector
Model Designation : See Certificate
Certificate No. : R 50461253 0001
Report No. : 50350053 001

Dear Maggie Liu,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body



Zhao Xinhua

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询