



Product Service

# CERTIFICATE

No. B 106223 0001 Rev. 00

**Holder of Certificate:** SUNTREE ELECTRIC GROUP CO.,LTD

Xinguang Industrial Zone, Liushi Town  
325603 Yueqing City, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Production  
Facility(ies):  
Certification Mark:**

103722



**Product:**

**Connector  
(Connectors for Photovoltaic System)**

**Model(s):**

**PMCN40-CM, PMCN40-CM-01, PMCN40-PM,  
PMBC40, PMBC50**

**Parameters:**

Rated Voltage: 1500 V d.c.  
Rated Current: 40 A  
Protection Class: II  
Degree of Protection: IP68 (1m, 1h)  
Ambient Temperature: -40 °C to +85 °C

**Tested according to:** IEC 62852(ed.1)  
EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 64290190058601A  
**Valid until:** 2024-08-20

**Date,** 2019-10-18

  
( Symbol Zhao )